

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-1597:113 Page 1 of 1

CATEGORY: Annunciator

LISTEE: TEPG-US, 91 Technology Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 Fax (978) 731-8881

DESIGN: Model 430628 remote LCD annunciator. Refer to listee's printed data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number, electrical rating and UL label.

APPROVAL: Listed as an annunciator for use with listee's separately listed fire alarm control units. Refer to listee's Installation Instructions Manual for details.

XLf: 7120-0026:225

04-09-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager